MITSUBISHI ELECTRIC Inverter Sales and Service

Firmware Upgrade for the General-Purpose Inverter Option FR-PU07

Thank you for your continued patronage of Mitsubishi Electric drive control products. The firmware of the general-purpose inverter option FR-PU07 will be upgraded to improve functionality.

1. Products Affected

FR-PU07, FR-PU07BB, and FR-PU07BB-L

2. Details of the Change

(1) Addition of supported inverters

FR-E800 series inverters*1 (not including the FR-E800-(SC)E) will be supported. For supported functions, refer to the FR-PU07 Instruction Manual.

*1 FR-E800 inverters manufactured in May 2020 or later.

(2) Change of the number of fault records

Up to 10 fault records can be displayed for FR-E800 inverters.

(3) Warning/fault indications

The following indications will be added.

| | Indication | Name | Supported model |
|---------|------------|--|-------------------------------|
| Warning | LHP | Multi-turn count excess | FR-A800 with FR-A8APS |
| | RD | Backup in progress | FR-A800 and FR-F800 |
| | WR | Restoration in progress | FR-A800 and FR-F800 |
| | EHR | Ethernet communication fault | FR-A800, FR-F800, and FR-E800 |
| | DIP | Duplicate IP address | FR-A800, FR-F800, and FR-E800 |
| | IP | IP address fault | FR-A800, FR-F800, and FR-E800 |
| | SE | Incorrect parameter setting | FR-E800 |
| Fault | E.LOH | Reactor overheat | FR-A802 with FR-A8AVP |
| | E.VER | Invalid version | FR-A802 with FR-A8AVP |
| | E.EF | External fault during output operation | FR-A800 |
| | E.EHR | Ethernet communication fault | FR-A800, FR-F800, and FR-E800 |
| | E.CMB | Board combination fault | FR-E800 |

3. Date of Change

The change will be sequentially applied to the products manufactured in August 2020 or later.

4. Product Identification

The firmware-upgraded products will have a symbol (alphabetical letter) in the following table or later. The symbol will be found on the back of the product.

* For the FR-PU07BB(-L), the symbol is indicated inside of its back cover.

| Model | Symbol (alphabetical letter) | |
|-------------|------------------------------|--|
| FR-PU07 | U | |
| FR-PU07BB | К | |
| FR-PU07BB-L | K | |

Example of the back of the FR-PU07



| of | Date of issue: July 2020 Modified date: September 2021 | Title | Firmware Upgrade for the General-Purpose Inverter Option FR-PU07 | Mitsubishi Electric Corp., Nagoya Works 5-1-14 Yada-minami, Higashi-ku, Nagoya 461-8670 Tel.: +81 (52) 721-2111 Main line |
|----|--|-------|--|---|
|----|--|-------|--|---|