

MITSUBISHI ELECTRIC Inverter

Sales and Service

No. 744E

Appearance Change for the FR-E800 Series Inverters

Thank you for your continued patronage of Mitsubishi Electric drive control products. For the FR-E800 series inverters, in which the motor temperature is not observed directly, the Inverter Safety Guideline has described that "Motor overtemperature sensing is not provided by the drive" (in 7.2 Instructions for UL and cUL) based on the UL standard requirements. The same sentence will be printed on the inverter's front cover since the UL certification body pointed out that the sentence must also be indicated on the product body. The change does not affect the quality, performance, or specifications of the products.


1. Products Affected

FR-E800 series

2. Details of Change

The indication enclosed in red will be added on the front cover of the inverter.

(Example) Appearance of the front cover



3. Date of Change

Country of origin	Date of Change
MADE IN JAPAN	The change will be applied to the April 2023 production or later. * Depending on the production condition, the change may be applied to the products manufactured in March 2023.
MADE IN CHINA	The change will be applied to the April 2023 production or later.

4. Product Identification

The products can be identified visually.

Date Of issue	March 2023	Title	Appearance Change for the FR-E800 Series Inverters	Mitsubishi Electric Corp., Nagoya Works 5-1-14 Yada-minami, Higashi-ku, Nagoya 461-8670 Tel.: +81 (52) 721-2111 Main line