

[Issue No.] T30-0004

[Page] 1/1

[Title] Condition of Lloyd type approval system for QnAS Series

[Date of Issue] Mar. 2000

[Relevant Models] All models in QnAS Series

Thank you for your continued patronage of the Mitsubishi general-purpose PLC QnAS Series.

Lloyd Type Approval system certified MELSEC- QnAS Series for use in use of environmental category ENV2 as specification No.1-1996. The following described the detail.

Whereas

[Details]

• **Condition**

(1) Working ambient temperature

The working ambient temperature specified in the Mitsubishi PLC general specifications differ from the working ambient temperature specified in the Environment Class ENV2 of the Lloyd Type Approval System as specified in Lloyd Register's test specification No.1-1996.

| | Mitsubishi PLC general specifications | Lloyd Type Approval System |
|-----------------------------|--|-----------------------------------|
| Working ambient temperature | 0°C to +55°C | +5°C to +55°C |

Use the models within the working ambient temperature range specified in the Lloyd Type Approval System.

2) QnAS Series installation

When installing the QnAS Series, use a fitting (A6SFX) as shown below.

