



# 中国国家强制性产品认证证书

证书编号: 2002010307025604

## 委托人名称、地址

三菱电机株式会社福山制作所  
日本国广岛县福山市绿町1番8号

## 生产者(制造商)名称、地址

三菱电机株式会社福山制作所  
日本国广岛县福山市绿町1番8号

## 生产企业名称、地址

三菱电机株式会社福山制作所  
日本国广岛县福山市绿町1番8号

## 产品名称和系列、规格、型号

具有剩余电流保护的断路器

NV250-HW Ue:AC230V, AC380V, AC400V, AC415V; In:125A, 150A, 175A, 200A, 225A;  
过电流脱扣器类型:热磁式; Ue:AC230V Icu:100kA, Ics:25kA;  
Ue:AC380V/AC400V/AC415V Icu:50kA, Ics:13kA; 额定剩余动作电流(I $\Delta$ n):  
30mA, 30/100/500mA, 100/200/500mA(非延时型) 100/200/500mA, 100/300/500mA(延  
时型); 额定剩余动作类型: A型(非延时型, 延时型); 漏电脱扣器的类型:电子式;  
剩余接通和分断能力(I $\Delta$ m): 25%Icu; 使用类别:A; 极数: 3P, 4P

## 产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2011年01月30日 有效期至: 2016年01月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2002年12月18日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0361902



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2002010307025604

## NAME AND ADDRESS OF THE APPLICANT

Mitsubishi Electric Corporation Fukuyama Works  
1-8, Midorimachi Fukuyama-city Hiroshima-Pref.

## NAME AND ADDRESS OF THE MANUFACTURER

Mitsubishi Electric Corporation Fukuyama Works  
1-8, Midorimachi Fukuyama-city Hiroshima-Pref.

## NAME AND ADDRESS OF THE FACTORY

Mitsubishi Electric Corporation Fukuyama Works  
1-8, Midorimachi Fukuyama-city Hiroshima-Pref.

## NAME, MODEL AND SPECIFICATION

Circuit-breaker Incorporating Residual Current Protection

NV250-HW Ue:AC230V, AC380V, AC400V, AC415V; In:125A, 150A, 175A, 200A, 225A;  
thermal and magnetic; Ue:AC230V Icu:100kA, Ics:25kA;  
Ue:AC380V/AC400V/AC415V Icu:50kA, Ics:13kA; IΔn:  
30mA, 30/100/500mA, 100/200/500mA(Non delay time)  
100/200/500mA, 100/300/500mA(delay time);; Characteristic of Residual  
current operating: A type; Type of Residual current operating:Electronic;  
IΔm: 25%Icu; Utilization Category:A; 3P,4P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Jan. 30, 2011      Date of expiry: Jan. 30, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec. 18, 2002

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0361902